

CERTIFICATE OF CONFORMANCE TO ASTM F3010

Koster American Corporation certifies that the following products meet the requirements of ASTM F3010-13 *Standard Practice for Two-Component Resin Based Membrane-Forming Moisture Mitigation Systems for Use Under Resilient Floor Coverings* when installed according to the manufacturer's instructions on properly prepared concrete.

	Two-component resin based product	Water Vapor Permeance ^{1,2} ASTM E96 water method 73°F/50%RH grains·hr ⁻¹ ·ft ⁻² ·in. Hg ⁻¹
Criteria:	Yes	<i>Not exceed 0.1</i>
Product:		
KOSTER VAP I® 2000 Zero VOC	Yes	0.056
KOSTER VAP I® 2000 FS	Yes	0.047
KOSTER VAP I® 2000 UFS	Yes	0.060

Notes

1. Products applied at 100 square feet/gal to ICRI CSP3 abrasively blasted concrete.
2. Net permeance of coating corrected for uncoated substrate concrete.



Basil Mewes
President

e-mail: basil@kosterusa.com

Phone: (757) 425-1206